



ADDENDUM NO. 1

DATE: JULY 16, 2020

MIDDLESEX COUNTY

EASTERN MIDDLESEX COUNTY REGIONAL WATER SYSTEM

VERTICAL BOOSTER PUMP SKID AND CONTROL SYSTEM BID DOCUMENT

GENERAL INFORMATION:

1. Bids shall be hand delivered or submitted by mail. Electronic submittals are not accepted.
2. Hand delivered bids shall be dropped off at the Middlesex County Treasurer's Office and must call 804-758-4330 for notification of bid submittal.

BID DOCUMENT:

1. Technical Specification Section 11211
 - a. Delete 2.11.B.1.a in its entirety and replace it with
"The booster pump pumping system will operate to maintain a constant pressure at a pressure transducer on the distribution header. At a minimum, all pump flow shall meet specified flows within the specification."
 - b. Delete 2.11.B.2.a in its entirety and replace it with
"The booster pump pumping system will operate to maintain a constant pressure at a pressure transducer on the distribution header. At a minimum, all pump flow shall meet specified flows within the specification."
 - c. Add 1.01.F
"Header piping and sizes shown are minimum. The supplier shall provide appropriately sized header piping based on their pump and skid selection. Maximum velocity shall not exceed 8.0 ft/s."

END OF ADDENDUM NO. 1